

# **Weather-Rated Economics of Gas Turbine Installations**

## **A Call for an Alternate Rating Point**

**07 December, 2005**

Presented at PowerGen International 2005  
Las Vegas, NV, USA

Tom Tillman

Peter Armstrong  
Director Business Development  
parmstrong@tas.com

**Turbine Air Systems, Ltd**  
**4300 Dixie Drive**  
**Houston, TX 77021**  
**713-877-8700**  
[www.tas.com](http://www.tas.com)



***TURBINE AIR SYSTEMS***

## Introduction

The economic status of most of the US's gas turbine installations remains bleak, as of late 2005. The gas-fired generation capacity that once showed so much promise now struggles to maintain a foothold in real contributions to the national grids. The gas turbine is far from dead, yet the immediate future of this technology looks to be much less robust as compared to the boom days of 1998-2001.

The US power industry now lives with remarkably low capacity factors for gas-fired gas turbine plants. Gas-fired Combined Cycle (CC) plants were supposed to take on the bulk of the base load in the US, allowing older coal-fired plants to retire gracefully. Instead, the market has called for a renewed emphasis on coal-fired operations. Many of the older coal plants are receiving a new economic lease on life through renewed capital improvements that were needed to clean up emissions. Future greenfield coal plants promise to be extremely clean as compared to previous generations. In fact, the cleanest coal-fired technology in the next decade should be the Integrated Gasification Combined Cycle (IGCC) that marries the low cost of coal with the high efficiency of gas turbine combined cycles. Therefore, the future of coal looks to be headed "back to the future" with gas turbines.

The question is, "where does that leave current and future *gas-fired* gas turbines?" The obvious answer is that these plants will continue to serve, and will even grow in numbers, but at rather low capacity factors. Because both base load and peaking period electrical demand continues to rise unabated, gas-fired gas turbines will still have their place in the generation mix. However, CC plants that were designed to be base-load operations are running at intermediate load at best, and even are forced into daily peaking operations.

Unable to find an attractive market for their power, many CC plants from the boom era have defaulted on their debt obligations, wiping out not only equity positions of their developers and investors, but also much of the capital covered by debt. A CC plant, which may have originally been valued at \$600 per kW when natural gas was originally priced at \$2 per mmBTU, might have had a residual value of \$300 per kW when gas then rose to \$5. One has to wonder if we will soon face another round of CC plant "fire sales" due to the plant devaluation associated with gas prices exceeding \$10.


Just how bad is the capacity factor issue? One of the best representations of this phenomenon has recently been provided by Jeffrey Phillips of the Electric Power Research Institute (EPRI). In an article<sup>1</sup> published earlier in 2005, he graphically (next page) demonstrates the declining annual capacity factors for CC plants in the US.

While the downward trend in average annual capacity factor (the red line) is frightening enough, what is even more noteworthy is the increasing spread (black line) between

---

<sup>1</sup> Turbomachinery International, July 2005, Jeffrey Phillips "Putting Combined Cycles Back in Use"

winter capacity factor as compared to summer. In simplistic terms, the summer capacity factor for 2004 was double that of the winter capacity factor. The trend is clearly for this seasonal spread to grow, as gas prices remain high relative to coal. It will be interesting to see what this information looks like for 2005, when natural gas prices just about doubled over the course of the year.



**Figure 1 – Monthly and Annual Capacity Factors of US Combined Cycle Fleet. Source: EPRI Report 1008329, March 2005, *Gas Market Transition: Impacts of Power Generation on Gas Pricing Dynamics*.**

For 2004, the capacity factor low point was 18% for January, and the high point 40% for August. However, the above figure shows monthly averages. If this figure could show daily and average hourly capacity factors, it is easy to surmise that the weekday capacity factors would be much higher than the weekend/holidays. Further, the capacity factors for the daily peak hours would be much higher than the overnight hours. To put this in perspective, a typical CC operating realm in the summer is a 5 X 16 dispatch block. This is 80 hours per week, or 47% capacity factor. Therefore, the graphical spread between winter and summer operating seasons in the figure above actually understates the overall spread in capacity factor, experiencing a nadir in off-peak shoulder-season hours, as compared to the super-peak of summer daytime operations.

When these CC plants were in the planning and design phase some five to seven years ago, the economic assumption for capacity factor was for greater than 80% for most plants, and as much as 95% by the most optimistic. Accordingly, several design assumptions have come back to haunt those original assumptions. The issue that gets

the most press is the fact that daily cycling of CC plants is causing problems with the Heat Recovery Steam Generator (HRSG) and steam turbine plant. Daily cycling is also causing the “engine starts” portion of many Long Term Service Agreements (LTSA) to get rather expensive.

The second design issue from that period, much less publicized, is that the plant was probably optimized for an ambient temperature based on the local annual average temperature, or at best, the summer average temperature. Many plants were optimized for temperatures that ranged from 59°F (10 C) and 77°F (25C). This issue has been the subject of past papers by TAS. In those papers, we demonstrated that optimization of a CC plant for high ambient temperatures, say 95°F (35C), when including turbine inlet cooling (TIC), resulted in better than a 53.7 MW<sup>2</sup> increase in power for a typical 500 MW *nameplate* plant. If that plant were in fact optimized for a lower *summer average* temperature such as 77°F, as compared to 95°F, the loss in power would be approximately 2.5 MW<sup>3</sup> at the peak earning periods, even with the same capital costs.




Figure 2 – Gas Turbine Power Output, as compared to the compressor Inlet Air Temperature. The slope of this line is called the “Lapse Rate”. The gas turbine chosen for this figure is a very common aeroderivative peaker. All gas turbines have unique lapse rates.

<sup>2</sup> Tillman, Turbine Air Systems, PowerGen International 2003, “Comparison of Power Enhancement Options for Greenfield Combined Cycle Power Plants”

<sup>3</sup> Tillman, Turbine Air Systems, PowerGen International 2004, “Comparison of Power Enhancement Options for Retrofit to Combined Cycle Power Plants, Phase 2 Report”

EPRI's Phillips contends that one potential use for US CC plants suffering from low capacity factor would be to repower<sup>4</sup> them as the starting point for a new IGCC project. This would certainly save significant capital costs as compared to a new power block, albeit that a considerable amount of modification to the existing power block would still be required to allow the units to run on syn-gas (a combination of carbon monoxide and hydrogen). This is a commendable idea, and will probably be implemented. However this concept is not likely to make a large enough impact on the total GT market to save many CC installations from further devaluations.

Dedicated peakers, mostly simple-cycle (SC) aero-derivative turbines, continue to be slowly added in areas strapped for increased peaking load. In general for gas turbines, the US SC market appears to be stronger than the CC market, but only in relative terms. Certainly, SC peakers that will be installed in the coming years will be required only to serve the summer peaking load caused mostly by air conditioning. In fact, the so-called "generation glut" of the past four years in the US is not a glut at all during hot summer afternoons. There is once again growing strain in regions such as California and New England with peak capacity reserve margins now all but eliminated in the summer season.

The point now stands – "What have we learned in the US power industry, regarding the design of these GT assets?" The answer, we believe, is that the industry failed to consider that the most profitable period of operation for CC plants, perhaps the *only* period of profitable operation, is the summer daytime peaks. This trend was as predictable then as its continuation continues to be now.

On an international basis, SC and CC installations continue to grow in the tropical and subtropical regions of the world. Growth continues unabated in China, Southeast Asia and the Middle East. In fact, in these regions of the world, their seasons are predominantly "hot" and "hotter".

Our contention is that gas turbine assets, including CC plants, not only should be optimized for hot weather operations, but also should be *rated* at high ambient temperatures. The current rating of gas turbines is the "ISO" point of 59°F (15C). Even though many combined cycle plants are sometimes tested at prevailing temperatures, the test data is usually then "corrected" back to the standard ISO design point of 59°F.

In today's markets, gas turbine assets are called into duty at warm-to-hot ambient temperatures, and also at very cold temperatures. We don't hear of cold weather *electric* supply problems, even though there is sometimes tightness in fuel supply. The point is that gas turbines are *least* likely to run in the moderate ambient temperature band, centered ironically around 59°F! Therefore, the current ISO rating point has become irrelevant, and a relic of past practices. We believe that the economic reality of gas turbine operations dictate that a new, if perhaps alternative, rating point is now warranted.

---


<sup>4</sup> Turbomachinery Int'l, July 2005, Jeffrey Phillips "Putting Combined Cycles Back in Use"

## Making the Case for an Alternative Design Point

The ISO rating point of 59°F (15 C) and 40% RH is ingrained in the memory of every power engineer that works with gas turbines. We now recommend a new, alternative-rating point for gas turbines that represents the economic reality of operations for GTs. Such a convention would not be a first, because marine applications for engines (including gas turbines) have long used a much higher ambient temperature, 100°F.<sup>5</sup>

The new rating point that we recommend is 95°F (35 C) and 60% RH. There are several reasons for this point.


- A line drawn between the current ISO rating point and the proposed alternative rating point is a good “best fit” match for the design conditions of several major US cities. These hot weather design points are prescribed by the American Society of Refrigeration Heating and Air-conditioning Engineers (ASHRAE). This reference is considered the most authoritative source of design weather data for a single “snap-shot” temperature and humidity point.



**Figure 3 – ASHRAE Design Conditions for several US locations, plotted as RH vs. ambient Dry Bulb temperature in degrees F.**

<sup>5</sup> MIL-E-17341C, 1962, 1970 “Military Specification, Engines, Gas Turbine, Propulsion and Auxiliary Naval Shipboard”, specifies 100 F

- These ASHRAE design points are also published for hundreds of cities around the globe. Most specifying engineers and owners recognize this data reference. The concept of a single “best fit” line is harder to establish in the span of global locations. Nonetheless, the 35 C design point is a reasonable proxy for summer design conditions internationally, as it is in the US. For the Persian Gulf Region (as in the US Desert Southwest), the design point understates the design dry bulb temperature and overestimates the humidity conditions. However, as in the previous figure, the argument is to move as far as reasonably necessary from the current ISO rating point as possible, not to cover every possible extreme.



**Figure 4 – ASHRAE Design Conditions for several international locations, plotted as RH vs. ambient Dry Bulb temperature in degrees C.**

- Like 59°F and its SI counterpart of 15 C, the 95°F / 35 C temperature pairing is at a whole number for each scale. This makes the point as attractive to those countries that still use the Fahrenheit scale, as well as the remainder of the world who uses Celsius (Centigrade) scale.
- Heat rejection equipment for dry chilled water applications is often rated at 95°F (35 C), as by example ARI 590-1999.

- Heat rejection for water-cooled chiller applications is determined by a “wet bulb” (WB) temperature of 75°F, per ARI 550-1990, which is tantalizingly close to the WB temperature that corresponds to 95°F / 60% RH (actually 75.06 F).

| City               | State | Country   | Dry Bulb 0.4% | MCWB |
|--------------------|-------|-----------|---------------|------|
| Los Angeles        | CA    | USA       | 85            | 64   |
| Las Vegas          | NV    | USA       | 108           | 66   |
| Chicago            | IL    | USA       | 91            | 74   |
| Houston            | TX    | USA       | 96            | 77   |
| New York City      | NY    | USA       | 91            | 74   |
| Miami              | FL    | USA       | 91            | 77   |
| Atlanta            | GA    | USA       | 93            | 75   |
| Paris              |       | France    | 86            | 69   |
| Tokyo              |       | Japan     | 91            | 78   |
| Beijing            |       | China     | 94            | 71   |
| Shanghai           |       | China     | 94            | 81   |
| Jeddah             |       | Saudi     | 104           | 72   |
| Doha               |       | Qatar     | 109           | 71   |
| Rio de Janeiro     |       | Brazil    | 102           | 79   |
| Dubai              |       | UAE       | 107           | 75   |
| Kuala Lumpur       |       | Mayalasia | 94            | 78   |
| Seoul              |       | So Korea  | 89            | 77   |
|                    |       |           |               |      |
| Average            |       |           | 95.6          | 74.0 |
| Standard Deviation |       |           | 7.59          | 4.65 |

**Table 1, ASHRAE DB and MCWB design points for several major cities**

It is easy to put together a list of major international cities and the ASHRAE design conditions for Dry Bulb temperature and its Mean Coincident Wet Bulb (MCWB) temperature. As one can see, the temperatures tend to fall to the 95 DB / 75 MCWB pairing (this also can be described as 95F and 40% RH).

It is particularly critical that the proper *coincident* RH value is quoted for the design dry bulb temperature. This is the overwhelming first error that we see in design-basis specifications for gas turbine projects. The error is usually manifested in describing the maximum site RH in a way that it is *coincident* with the maximum annual dry bulb temperature. Such extremes never occur simultaneously. In fact, power engineers would do well to avoid “RH” altogether and to use the more appropriate term of *coincident* WB. This admonition might seem strangely unnecessary to veteran engineers who have worked with cooling towers for decades. However, the newer generation of engineers, who might be wizards at CAD and FEA, seem blissfully unaware of even rudimentary psychrometric principles.



## Weather-Leverage Capital Cost of Gas Turbine Plants

When an Owner or an engineer asks a question regarding a particular gas turbine, the usual first question would be “what is its output”? To date, the proper answer would be that “its output at the *ISO Rating Point of 59°F (35C)* would be \_\_\_ MW.” In this section, we ask the output question with more precision “what is the *useful* output of this gas turbine during the most likely temperature of profitable operation?”

One can look to references such as *Gas Turbine World's* annual Handbook<sup>6</sup> where all of the available gas turbines are listed with such standard data, all at the ISO rating point. One of the most interesting features of such a list is to look at the *unit cost* of gas turbines, and their built-out CC plants. The unit cost is expressed as “\$ per kW”. As such, this parametric figure is a *value* determination. Of course, this figure needs to be considered in light of heat rate parametric of “BTU per kWhr”; yet even this efficiency proxy is dependent on rating at the common ISO point.

| GT OEM | Model     | Version     | ISO Output,<br>gross<br>kW | Output at 95F,<br>gross<br>kW | delta<br>power<br>kW | delta<br>temp<br>°F | Lapse Rate<br>kW per ° | Specific<br>Lapse Rate<br>% per °F |
|--------|-----------|-------------|----------------------------|-------------------------------|----------------------|---------------------|------------------------|------------------------------------|
| Alstom | GT11      | N2          | 115,350                    | 99,611                        | (15,739)             | 36                  | (437)                  | -0.38%                             |
| Alstom | GT11      | NM          | 89,600                     | 75,638                        | (13,962)             | 36                  | (388)                  | -0.43%                             |
| Alstom | GT13      | E2          | 172,300                    | 147,661                       | (24,639)             | 36                  | (684)                  | -0.40%                             |
| GE     | PG5371    | PA          | 26,555                     | 22,009                        | (4,546)              | 36                  | (126)                  | -0.48%                             |
| GE     | PG6581    |             | 42,600                     | 36,706                        | (5,894)              | 36                  | (164)                  | -0.38%                             |
| GE     | PG7241FA  | SC          | 171,100                    | 147,000                       | (24,100)             | 36                  | (669)                  | -0.39%                             |
| GE     | PG7241FA  | CC          | 498,000                    | 454,800                       | (43,200)             | 36                  | (1,200)                | -0.24%                             |
| GE     | LM2500    | PE          | 22,775                     | 19,689                        | (3,086)              | 36                  | (86)                   | -0.38%                             |
| GE     | LM6000    | Sprint, DLN | 46,857                     | 38,330                        | (8,527)              | 36                  | (237)                  | -0.51%                             |
| GE     | LM6000    | PC w/o IGV  | 43,915                     | 29,457                        | (14,458)             | 36                  | (402)                  | -0.91%                             |
| GE     | LM6000    | PD, DLN     | 42,533                     | 30,849                        | (11,684)             | 36                  | (325)                  | -0.76%                             |
| MHI    | MF111B    |             | 14,838                     | 12,517                        | (2,321)              | 36                  | (64)                   | -0.43%                             |
| PWPS   | FT-8      | Twin        | 51,350                     | 41,556                        | (9,794)              | 36                  | (272)                  | -0.53%                             |
| PWPS   | FT-8+     | Twin        | 56,220                     | 46,482                        | (9,738)              | 36                  | (271)                  | -0.48%                             |
| RR     | Trent 50  |             | 52,157                     | 40,039                        | (12,118)             | 36                  | (337)                  | -0.65%                             |
| Solar  | Titan 130 |             | 14,245                     | 11,657                        | (2,588)              | 36                  | (72)                   | -0.50%                             |
| Solar  | Taurus 60 | T7800       | 5,500                      | 4,641                         | (859)                | 36                  | (24)                   | -0.43%                             |
| SWPC   | GT 10     | B           | 24,630                     | 20,319                        | (4,311)              | 36                  | (120)                  | -0.49%                             |
| SWPC   | GT 10     | C           | 29,060                     | 24,027                        | (5,033)              | 36                  | (140)                  | -0.48%                             |
| SWPC   | GT 35     |             | 17,015                     | 11,724                        | (5,291)              | 36                  | (147)                  | -0.86%                             |
| SWPC   | GTX100    |             | 43,000                     | 36,646                        | (6,354)              | 36                  | (177)                  | -0.41%                             |
| SWPC   | W251      | B11-12      | 49,500                     | 41,527                        | (7,973)              | 36                  | (221)                  | -0.45%                             |

Table 2 Lapse Rate between 59F and 95F for selected gas turbines

If such lists of gas turbines were to be published at the proposed alternative rating point of 95°F (35C), the list would look strikingly different. First, all of the gas turbine outputs would be some 10 to 30% lower; and the heat rates would be approximately 5% higher. The drop of GT output vs. a change in temperature can be easily quantified, and is called the “lapse rate”. Lapse rate can be expressed as change in kW per degree, or

<sup>6</sup> Pequot Publishing

percentage change per degree. The previous table shows several common gas turbines, representing both relatively older technology and newest technology.

Yet to determine the actual value of the particular gas turbine at the alternative rating point, the following table is provided. This table lists the same gas turbines; but lists the installed cost of the unit. The power output is given at both the ISO and the alternate rating points. Using the installed cost, we can determine the relative value of each turbine at the more economically relevant alternate design point. It is here that we see the real unit cost of a gas turbine is much higher than expected when considered during the real high-temperature operating periods.

For data consistency Costs and output for these tables are taken from multiple runs of Thermoflow Software's GTPro and PEACE programs.

| GT OEM | Model     | Version     | Bare Cost<br>USD | Installed Cost<br>USD | ISO Output,<br>gross<br>kW | Unit Cost @<br>ISO,<br>\$/ kW | Output at<br>95F, net<br>kW | Net Unit<br>Cost @ 95F<br>\$/ kW |
|--------|-----------|-------------|------------------|-----------------------|----------------------------|-------------------------------|-----------------------------|----------------------------------|
| Alstom | GT11      | N2          | \$21,430,000     | \$39,423,560          | 115,350                    | \$342                         | 98,400                      | \$401                            |
| Alstom | GT11      | NM          | \$16,778,000     | \$31,897,059          | 89,600                     | \$356                         | 74,570                      | \$428                            |
| Alstom | GT13      | E2          | \$29,477,000     | \$52,883,930          | 172,300                    | \$307                         | 146,000                     | \$362                            |
| GE     | PG5371    | PA          | \$8,400,000      | \$16,429,308          | 26,555                     | \$619                         | 21,610                      | \$760                            |
| GE     | PG6581    |             | \$11,832,000     | \$22,007,985          | 42,600                     | \$517                         | 36,130                      | \$609                            |
| GE     | PG7241FA  | SC          | \$31,250,000     | \$50,701,500          | 171,100                    | \$296                         | 146,500                     | \$346                            |
| GE     | PG7241FA  | CC          | \$0              | \$212,400,000         | 498,000                    | \$427                         | 442,700                     | \$480                            |
| GE     | LM2500    | PE          | \$9,569,000      | \$16,958,763          | 22,775                     | \$745                         | 19,370                      | \$876                            |
| GE     | LM6000    | Sprint, DLN | \$13,670,000     | \$24,032,157          | 46,857                     | \$513                         | 37,800                      | \$636                            |
| GE     | LM6000    | PC w/o IGV  | \$10,910,000     | \$20,264,567          | 43,915                     | \$461                         | 29,000                      | \$699                            |
| GE     | LM6000    | PD, DLN     | \$11,507,000     | \$20,951,135          | 42,533                     | \$493                         | 30,390                      | \$689                            |
| MHI    | MF111B    |             | \$6,512,000      | \$12,121,797          | 14,838                     | \$817                         | 12,260                      | \$989                            |
| PWPS   | FT-8      | Twin        | \$15,746,000     | \$28,145,580          | 51,350                     | \$548                         | 40,950                      | \$687                            |
| PWPS   | FT-8+     | Twin        | \$17,189,000     | \$30,250,300          | 56,220                     | \$538                         | 45,830                      | \$660                            |
| RR     | Trent 50  |             | \$17,094,000     | \$29,124,686          | 52,157                     | \$558                         | 39,470                      | \$738                            |
| Solar  | Titan 130 |             | \$5,081,000      | \$9,979,823           | 14,245                     | \$701                         | 11,410                      | \$875                            |
| Solar  | Taurus 60 | T7800       | \$2,174,000      | \$4,935,830           | 5,500                      | \$897                         | 4,522                       | \$1,092                          |
| SWPC   | GT 10     | B           | \$7,871,000      | \$15,365,096          | 24,630                     | \$624                         | 19,950                      | \$770                            |
| SWPC   | GT 10     | C           | \$8,910,000      | \$16,404,096          | 29,060                     | \$564                         | 23,591                      | \$695                            |
| SWPC   | GT 35     |             | \$6,292,000      | \$12,132,993          | 17,015                     | \$713                         | 13,110                      | \$925                            |
| SWPC   | GTX100    |             | \$12,351,000     | \$22,574,088          | 43,000                     | \$525                         | 36,090                      | \$625                            |
| SWPC   | W251      | B11-12      | \$13,357,000     | \$24,648,037          | 49,500                     | \$498                         | 40,840                      | \$604                            |

Table 3 UNIT COST at rating points of 59F and 95F for selected gas turbines

In Table 3, we see that the unit cost of the GT is much higher when rated at the alternate design point. The reason for using this data is because what we really want to know is what is the relative value of each GT at the period when it will be “used and useful”.

Therefore, if there is a significant decrease in useful power, and hence a similar decrease in value, then we turn to the consideration of what is the additional TIC value proposition for those plants so equipped. In the following table we see the relative net improvement in power output at the alternative rating point of 95°F. The before case has no TIC, and the after case has TIC with chilling down to 50°F (10C). The auxiliary load required to operate the chiller plant has been netted out of the after value.

| GT OEM | Model     | Version     |  | Output at 95F,<br>net<br>kW | Chilled<br>Output, net<br>kW | Power<br>Increase, net<br>% |
|--------|-----------|-------------|--|-----------------------------|------------------------------|-----------------------------|
| Alstom | GT11      | N2          |  | 98,400                      | 111,000                      | 12.8%                       |
| Alstom | GT11      | NM          |  | 74,570                      | 85,700                       | 14.9%                       |
| Alstom | GT13      | E2          |  | 146,000                     | 166,000                      | 13.7%                       |
| GE     | PG5371    | PA          |  | 21,610                      | 25,420                       | 17.6%                       |
| GE     | PG6581    |             |  | 36,130                      | 41,180                       | 14.0%                       |
| GE     | PG7241FA  | SC          |  | 146,500                     | 169,250                      | 15.5%                       |
| GE     | PG7241FA  | CC          |  | 442,700                     | 499,300                      | 12.8%                       |
| GE     | LM2500    | PE          |  | 19,370                      | 21,800                       | 12.5%                       |
| GE     | LM6000    | Sprint, DLN |  | 37,800                      | 45,560                       | 20.5%                       |
| GE     | LM6000    | PC w/o IGV  |  | 29,000                      | 43,240                       | 49.1%                       |
| GE     | LM6000    | PD, DLN     |  | 30,390                      | 41,700                       | 37.2%                       |
| MHI    | MF111B    |             |  | 12,260                      | 14,120                       | 15.2%                       |
| PWPS   | FT-8      | Twin        |  | 40,950                      | 50,060                       | 22.2%                       |
| PWPS   | FT-8+     | Twin        |  | 45,830                      | 54,190                       | 18.2%                       |
| RR     | Trent 50  |             |  | 39,470                      | 51,120                       | 29.5%                       |
| Solar  | Titan 130 |             |  | 11,410                      | 13,620                       | 19.4%                       |
| Solar  | Taurus 60 | T7800       |  | 4,522                       | 5,225                        | 15.5%                       |
| SWPC   | GT 10     | B           |  | 19,950                      | 23,650                       | 18.5%                       |
| SWPC   | GT 10     | C           |  | 23,591                      | 27,920                       | 18.4%                       |
| SWPC   | GT 35     |             |  | 13,110                      | 16,190                       | 23.5%                       |
| SWPC   | GTX100    |             |  | 36,090                      | 41,520                       | 15.0%                       |
| SWPC   | W251      | B11-12      |  | 40,840                      | 47,560                       | 16.5%                       |

**Table 4 Power increase due to TIC, at 95F Rating Point**

There is little argument that TIC systems can significantly increase the amount of power from a GT at these high ambient conditions. The only area of misunderstanding for some engineers is in the area of value proposition. That is, is the unit cost of a chilled gas turbine less than the unit cost of an unchilled gas turbine? Because, after all, we know that there is not an unlimited budget to provide auxiliary equipment to our power projects. The following table shows that although the capital costs increase for a chilled plant, the incremental power increases faster. Therefore, the relative value of the plant improves, indicating a decrease in unit cost in many cases greater than 15%.

| GT OEM | Model     | Version     | Installed Cost | Output at 95F, net | Net Unit Cost @ 95F | Installed Cost Chilled | Chilled Output, net | Unit Cost @ 95F, Installed | Unit Cost Change |
|--------|-----------|-------------|----------------|--------------------|---------------------|------------------------|---------------------|----------------------------|------------------|
|        |           |             | USD            | kW                 | \$/ kW              | USD                    | kW                  | \$/ kW                     |                  |
| Alstom | GT11      | N2          | \$39,423,560   | 98,400             | \$401               | \$44,113,256           | 111,000             | \$397                      | -0.8%            |
| Alstom | GT11      | NM          | \$31,897,059   | 74,570             | \$428               | \$35,891,674           | 85,700              | \$419                      | -2.1%            |
| Alstom | GT13      | E2          | \$52,883,930   | 146,000            | \$362               | \$59,025,382           | 166,000             | \$356                      | -1.8%            |
| GE     | PG5371    | PA          | \$16,429,308   | 21,610             | \$760               | \$18,256,644           | 25,420              | \$718                      | -5.5%            |
| GE     | PG6581    |             | \$22,007,985   | 36,130             | \$609               | \$24,154,674           | 41,180              | \$587                      | -3.7%            |
| GE     | PG7241FA  | SC          | \$50,701,500   | 146,500            | \$346               | \$56,701,500           | 169,250             | \$335                      | -3.2%            |
| GE     | PG7241FA  | CC          | \$212,400,000  | 442,700            | \$480               | \$224,400,000          | 499,300             | \$449                      | -6.3%            |
| GE     | LM2500    | PE          | \$16,958,763   | 19,370             | \$876               | \$18,273,515           | 21,800              | \$838                      | -4.3%            |
| GE     | LM6000    | Sprint, DLN | \$24,032,157   | 37,800             | \$636               | \$26,055,401           | 45,560              | \$572                      | -10.0%           |
| GE     | LM6000    | PC w/o IGV  | \$20,264,567   | 29,000             | \$699               | \$22,353,107           | 43,240              | \$517                      | -26.0%           |
| GE     | LM6000    | PD, DLN     | \$20,951,135   | 30,390             | \$689               | \$23,011,843           | 41,700              | \$552                      | -20.0%           |
| MHI    | MF111B    |             | \$12,121,797   | 12,260             | \$989               | \$13,264,137           | 14,120              | \$939                      | -5.0%            |
| PWPS   | FT-8      | Twin        | \$28,145,580   | 40,950             | \$687               | \$30,560,484           | 50,060              | \$610                      | -11.2%           |
| PWPS   | FT-8+     | Twin        | \$30,250,300   | 45,830             | \$660               | \$32,711,367           | 54,190              | \$604                      | -8.5%            |
| RR     | Trent 50  |             | \$29,124,686   | 39,470             | \$738               | \$31,478,755           | 51,120              | \$616                      | -16.5%           |
| Solar  | Titan 130 |             | \$9,979,823    | 11,410             | \$875               | \$11,075,352           | 13,620              | \$813                      | -7.0%            |
| Solar  | Taurus 60 | T7800       | \$4,935,830    | 4,522              | \$1,092             | \$5,538,968            | 5,225               | \$1,060                    | -2.9%            |
| SWPC   | GT 10     | B           | \$15,365,096   | 19,950             | \$770               | \$16,802,378           | 23,650              | \$710                      | -7.8%            |
| SWPC   | GT 10     | C           | \$16,404,096   | 23,591             | \$695               | \$18,605,143           | 27,920              | \$666                      | -4.2%            |
| SWPC   | GT 35     |             | \$12,132,993   | 13,110             | \$925               | \$13,756,030           | 16,190              | \$850                      | -8.2%            |
| SWPC   | GTX100    |             | \$22,574,088   | 36,090             | \$625               | \$24,499,581           | 41,520              | \$590                      | -5.7%            |
| SWPC   | W251      | B11-12      | \$24,648,037   | 40,840             | \$604               | \$27,053,295           | 47,560              | \$569                      | -5.7%            |

Table 5 TIC's Economic Improvement to Unit Cost at 95F Rating Point

| GT OEM | Model     | Version     | Installed Cost | Chilled Output, net | Installed Cost Chilled | net delta | TIC Cost     | TIC unit cost |
|--------|-----------|-------------|----------------|---------------------|------------------------|-----------|--------------|---------------|
|        |           |             | USD            | kW                  | USD                    |           |              | \$/ kW        |
| Alstom | GT11      | N2          | \$39,423,560   | 111,000             | \$44,113,256           | 12,600    | \$4,689,696  | \$372         |
| Alstom | GT11      | NM          | \$31,897,059   | 85,700              | \$35,891,674           | 11,130    | \$3,994,615  | \$359         |
| Alstom | GT13      | E2          | \$52,883,930   | 166,000             | \$59,025,382           | 20,000    | \$6,141,452  | \$307         |
| GE     | PG5371    | PA          | \$16,429,308   | 25,420              | \$18,256,644           | 3,810     | \$1,827,336  | \$480         |
| GE     | PG6581    |             | \$22,007,985   | 41,180              | \$24,154,674           | 5,050     | \$2,146,689  | \$425         |
| GE     | PG7241FA  | SC          | \$50,701,500   | 169,250             | \$56,701,500           | 22,750    | \$6,000,000  | \$264         |
| GE     | PG7241FA  | CC          | \$212,400,000  | 499,300             | \$224,400,000          | 56,600    | \$12,000,000 | \$212         |
| GE     | LM2500    | PE          | \$16,958,763   | 21,800              | \$18,273,515           | 2,430     | \$1,314,751  | \$541         |
| GE     | LM6000    | Sprint, DLN | \$24,032,157   | 45,560              | \$26,055,401           | 7,760     | \$2,023,244  | \$261         |
| GE     | LM6000    | PC w/o IGV  | \$20,264,567   | 43,240              | \$22,353,107           | 14,240    | \$2,088,541  | \$147         |
| GE     | LM6000    | PD, DLN     | \$20,951,135   | 41,700              | \$23,011,843           | 11,310    | \$2,060,708  | \$182         |
| MHI    | MF111B    |             | \$12,121,797   | 14,120              | \$13,264,137           | 1,860     | \$1,142,340  | \$614         |
| PWPS   | FT-8      | Twin        | \$28,145,580   | 50,060              | \$30,560,484           | 9,110     | \$2,414,904  | \$265         |
| PWPS   | FT-8+     | Twin        | \$30,250,300   | 54,190              | \$32,711,367           | 8,360     | \$2,461,067  | \$294         |
| RR     | Trent 50  |             | \$29,124,686   | 51,120              | \$31,478,755           | 11,650    | \$2,354,069  | \$202         |
| Solar  | Titan 130 |             | \$9,979,823    | 13,620              | \$11,075,352           | 2,210     | \$1,095,529  | \$496         |
| Solar  | Taurus 60 | T7800       | \$4,935,830    | 5,225               | \$5,538,968            | 703       | \$603,138    | \$858         |
| SWPC   | GT 10     | B           | \$15,365,096   | 23,650              | \$16,802,378           | 3,700     | \$1,437,283  | \$388         |
| SWPC   | GT 10     | C           | \$16,404,096   | 27,920              | \$18,605,143           | 4,329     | \$2,201,048  | \$508         |
| SWPC   | GT 35     |             | \$12,132,993   | 16,190              | \$13,756,030           | 3,080     | \$1,623,037  | \$527         |
| SWPC   | GTX100    |             | \$22,574,088   | 41,520              | \$24,499,581           | 5,430     | \$1,925,493  | \$355         |
| SWPC   | W251      | B11-12      | \$24,648,037   | 47,560              | \$27,053,295           | 6,720     | \$2,405,258  | \$358         |

Table 6 Unit Cost of TIC Installation, at 95F Rating Point

## Revisiting the “Performance Index” for Gas Turbines

Jerry Ebeling of Burns & MacDonnell was one of the early A/E pioneers in TIC. In an ASME paper delivered in 1995<sup>7</sup>, Kitchen and Ebeling described a formula for the “effectiveness” or “performance index”, measuring the impact of ambient temperature and inlet cooling on various gas turbines. The purpose of this work was to determine which GTs were the best *candidates* for inlet cooling. Each gas turbine design has a unique personality, based on specific airflow (pounds of air per kW-Hr), compression ratio, and firing temperature.

The *performance index* is updated in this paper in a different format by considering how much parasitic load is required for chiller operation, as compared to the gross power increase due to TIC. This new factor will look much like a chiller “Coefficient of Performance” (COP), but we will call the “Chiller Multiplier”. The terms are gross additional power associated with chilling divided by the amount of power required to operate the chiller. Because both terms have “kW” as units, this is a dimensionless parameter. This parameter shows that the amount of power required to run a chiller plant is returned at least four-fold, and in some exceptional cases, as much as 10X.

| GT OEM | Model     | Version     | Chilled Air Flow<br>kpph | tons<br>1.626 | kW per ton | chiller kW | gross delta power | Chiller multiplier |
|--------|-----------|-------------|--------------------------|---------------|------------|------------|-------------------|--------------------|
| Alstom | GT11      | N2          | 3,110                    | 5,057         | 0.75       | 3,793      | 16,393            | 4.32               |
| Alstom | GT11      | NM          | 2,504                    | 4,071         | 0.75       | 3,053      | 14,183            | 4.65               |
| Alstom | GT13      | E2          | 4,191                    | 6,815         | 0.75       | 5,111      | 25,111            | 4.91               |
| GE     | PG5371    | PA          | 986                      | 1,603         | 0.75       | 1,202      | 5,012             | 4.17               |
| GE     | PG6581    |             | 1,162                    | 1,889         | 0.75       | 1,417      | 6,467             | 4.56               |
| GE     | PG7241FA  | SC          | 3,580                    | 5,821         | 0.75       | 4,200      | 26,950            | 6.42               |
| GE     | PG7241FA  | CC          | 7,160                    | 11,642        | 0.75       | 8,400      | 65,000            | 7.74               |
| GE     | LM2500    | PE          | 542                      | 881           | 0.75       | 661        | 3,091             | 4.68               |
| GE     | LM6000    | Sprint, DLN | 1,038                    | 1,687         | 0.75       | 1,265      | 9,025             | 7.13               |
| GE     | LM6000    | PC w/o IGV  | 1,017                    | 1,653         | 0.75       | 1,240      | 15,480            | 12.49              |
| GE     | LM6000    | PD, DLN     | 1,016                    | 1,652         | 0.75       | 1,239      | 12,549            | 10.13              |
| MHI    | MF111B    |             | 443                      | 720           | 0.75       | 540        | 2,400             | 4.44               |
| PWPS   | FT-8      | Twin        | 1,343                    | 2,183         | 0.75       | 1,637      | 10,747            | 6.56               |
| PWPS   | FT-8+     | Twin        | 1,381                    | 2,245         | 0.75       | 1,684      | 10,044            | 5.97               |
| RR     | Trent 50  |             | 1,231                    | 2,002         | 0.75       | 1,501      | 13,151            | 8.76               |
| Solar  | Titan 130 |             | 388                      | 631           | 0.75       | 473        | 2,683             | 5.67               |
| Solar  | Taurus 60 | T7800       | 171                      | 278           | 0.75       | 209        | 912               | 4.37               |
| SWPC   | GT 10     | B           | 616                      | 1,001         | 0.75       | 751        | 4,451             | 5.93               |
| SWPC   | GT 10     | C           | 709                      | 1,153         | 0.75       | 864        | 5,194             | 6.01               |
| SWPC   | GT 35     |             | 744                      | 1,210         | 0.75       | 908        | 3,988             | 4.39               |
| SWPC   | GTX100    |             | 951                      | 1,546         | 0.75       | 1,160      | 6,590             | 5.68               |
| SWPC   | W251      | B11-12      | 1,373                    | 2,232         | 0.75       | 1,674      | 8,394             | 5.01               |

Table 7 TIC Multiplication Effect @ T<sub>1</sub>=95F (35C) and T<sub>2</sub>=50F (10C)

<sup>7</sup> Kitchen and Ebeling, 1995. Qualifying combustion turbines for inlet air cooling capacity enhancement. Paper 95-GT-266, *Int'l Gas Turbine and aerospace Cong.*, ASME

## Conclusion

Given the extremes that some project developers have gone to reduce the cost of equipment and installation, we believe that the value proposition of TIC has been completely missed. Many GTs in the past seven years did not benefit from TIC in the design of the plant. In their zeal to save capital cost, many decision-makers short-changed the operations of their unit in such a way that they have failed to optimize the operational economics of the plant.

Simply said – they failed to put their money into the part of the plant that would have made them the most profit.

If such developers were ever called in to regulatory hearings after a major summer blackout, they would certainly be questioned as to whether their capital-saving decisions were “prudent”. Unfortunately, “merchant” IPP peakers do not have the same obligation to serve that their regulated counterparts are required to meet. Nonetheless, this message needs to be understood by state regulators and regional ISO’s: plants that are said to be providing capacity to serve peak loads need to be “all there” when the call comes to deliver. The only way to reliably predict the capacity level of a GT at all ambient temperatures is to “flat-line” that GT’s performance with TIC.

How do we now put this lesson into practice for the present and the future?

- Rising natural gas prices may cause a further devaluation of gas turbine plants. If there is another round of bankruptcies or forced plant sales, then we recommend to prospective owners, and their bankers, to consider the useful output of the plant at this alternate rating point.
- Existing facilities without TIC may assess their profitability or break-even costs if they now added TIC as a retrofit, to capture the maximum number of MW-Hrs with the greatest spark spread.
- Future gas-fired simple cycle and combined cycle plants need to carefully assess their realistic capacity factors, and the most likely hours of operation. The engineers and financiers alike must optimize their plans for the most profitable peaking season. Inclusion of TIC will allow the plant to be optimized at a high ambient temperature.
- Future IGCC plants need to consider how to flat-line the output of their plants. The operation of the gasification system should not be driven by hourly changes in GT fuel demand. The inclusion of a TIC system will help to normalize operations during hot weather.